

## **FIRE RESISTANCE DECLARATION**

Tierre Group S.p.a. hereby declares that the following items:



In the following series:

Union Connectors FXUC  
End Plugs FXPF  
Reduced Union Connectors FXG

Have been tested accordingly to the following standard:

### **EN 61386-22**

Conduit systems for cable management  
Part 22: Particular requirements - Pliable conduit systems

And PASSED the

**glow-wire tests carried out at 750°C**

Cormano, 15th February 2019



TIERRE GROUP S.p.a.

Dott. Marco Regis

