

IMPACT RESISTANCE DECLARATION

Tierre Group S.p.a. hereby declares that the following items:



In the following series:

Union Connectors FXUC
End Plugs FXPF
Reduced Union Connectors FXG

Have been tested accordingly to the following standard:

EN 61386-24

Conduit systems for cable management
Part 24: Particular requirements – Conduit systems buried underground

And PASSED the

IMPACT TEST

performed in accordance with IEC 61386-24:2004 (1st Edition) used in conjunction with IEC 61386-1:2008 (2nd Edition)

Cormano, 15th February 2019



TIERRE GROUP S.p.a.

Dott. Marco Regis

