

FIRE RESISTANCE DECLARATION

Tierre Group S.p.a. hereby declares that the following items:



In the following series:

Gas Block double push-in system FXGB2P
Gas Block single push-in system FXGB1P
Gas Block single push-in system FXGB1P-BR

Have been tested accordingly to the following standard:

EN 61386-22

Conduit systems for cable management
Part 22: Particular requirements - Pliable conduit systems

And PASSED* the

glow-wire tests carried out at 750°C

Cormano, 15th February 2019



TIERRE GROUP S.p.a.

Dott. Marco Regis

* This declaration does not cover the plastic COMPRESSION NUT of the Gas Blocks